

ADDENDUM No. 2

Municipal Office Conversion
Township of North Stormont
Brockville, Ontario

PROJECT No.11200
June 11, 2024

The following Addendum shall be attached to and form part of the Tender Documents, as supplied by Township of North Stormont:

- 1. Can we install a high pressure line 2psig. To feed all the rooftop units, this would eliminate the high demand and hard to find pressure welder needed to weld the 2 1/2" gas line? We can install regulator on the roof to reduce the gas pressures to 7" W.C.*

That is an acceptable change.

All pipe sizing and regulator installation shall be in accordance with the Natural Gas and Propane Installation Code.

- 2. Please note that drawings A000, A100, A200, A300, A700 and A701 have been revised and copies have been attached to this addendum. Modifications have been showing with indicators noted as AD1. Description of work included added partition framed closets in the daycare area and modification of some existing windows in the daycare area.*

Prepared by:
Eastern Engineering Group Inc.
Consulting Engineers
June 11, 2024

*Addendum No.2
Page 1 of 1*

Attached: A000, A100, A200, A300, A700 and A701 (revised 2024-03-22)